



## RURAL MUNICIPALITY OF TACHÉ

<b>REFERENCE: PUBLIC WORKS</b>	<b>POLICY NO. PW-08-2016</b>
<b>TITLE: CONCRETE DRIVEWAY APPROACH SPECIFICATIONS</b>	<b>PAGES: 2</b>
<b>RESOLUTION NO: 2016-0834</b>	<b>DATE: November 8, 2016</b>
<b>REVIEW DATE:</b>	

### **Purpose:**

The purpose of this policy is to establish guidelines and conditions for the construction of concrete driveways within municipal a right-of-way, on streets that have existing lip or rolled curb type pavements.

### **Priorities**

For the purpose of driveway construction within a municipal right-of-way initiated by a property owner, to address connecting the concrete driveway to streets that have an existing lip or rolled curb type pavement.

### **Policy:**

#### **1.) Concrete Drive-Way Design**

Newly established concrete driveways within municipal rights-of-way that is on streets that have an existing lip or rolled curb type pavement to be constructed as per attached Schedule A and as per the following:

- a.) Maximum driveway width not to exceed 8.5 meters (28' feet)
- b.) A minimum 2% with a maximum 10% slope to be maintained falling from the home owner property line to the municipal road lip of curb.
- c.) Sub base shall be a minimum 100mm (4") of compacted 19mm (3/4") down limestone.
- d.) Concrete shall be a minimum 25 MPA 150mm (6") thick with a 600mm (24")

O.C. grid of 20mm (3/4") rebar.

- e.) A thickened edge starting 0.5 meters (20") before the municipal road curb finishing at existing concrete gutter (Municipal road edge). Thickened edge must be as thick or thicker than the municipal curb or road structure.
- f.) Thickened edge to include 20mm (3/4") diameter by 600mm (24") long epoxy coated rebar tied into the existing municipal curb at 600mm (24") O.C.
- g.) A 15mm (1/2") expansion joint is to be incorporated into the concrete driveway at the home owner property line.
- h.) If a curb stop is incorporated within the concrete driveway, an approved curb stop, and or manhole must be installed as per RM Utility Department direction.